



\*\*1455 Kleppe Lane, Sparks, NV 89431-6467 \* (775) 359-4712 \* fax: (775) 3597424  
\*\* Bachweg 3, CH-3401 Burgdorf, Switzerland \*(34) 423 2300 \* fax: (34) 423 2301  
\*\* 5 Woodlands Terrace #03-01 Singapore 738430 \* (65) 6367 0359 \* fax: (65) 6269 4110  
\* e-mail: [hawsmfg@singnet.com.sg](mailto:hawsmfg@singnet.com.sg) website: [www.hawasco.com](http://www.hawasco.com)

## 7602.15

---

### Specifications

**Tank:** 15 gallon capacity with 10 gallons of usable water offering increased eyewash flow duration, stainless steel with carrying handle. Air pressure filled to recommended 87 PSI. Pressure gauge, safety relief valve (set at 120 PSI). Additional relief valve built into tank cover.

**Heads:** Twin soft-flo patented ABS plastic anti-surge eyewash heads in Safety Green. Dust covers protect heads and automatically release with water pressure.

**Activation:** Stainless steel push flag operates a stay open chrome plated brass ball valve that is equipped with a stainless steel ball and stem.

**Stream Control:** Steady water flow under varying pressures assured with dual automatic pressure compensation devices.

**Preservatives:** Eyewash preservative additive to permit storage of water for several months included.(one bottle x 8 oz).



*\* picture shown after installation and for illustration purpose only*

#### Disclaimer:

Illustrations, detail drawings and accompanying descriptions describe standard features and sometimes optional variations of each product. They do not necessarily show or describe all the variations available. All designs are subject to change without notice and unless stated in the order, material will be furnished of design in effect at the time the order is filled. As may be necessary, we reserve the right to substitute materials and/or to make changes in design or other specification, as shown and described in any of our printed literature, without liability to purchasers.

Notice: Model shown meet **ANSI** standard and **OSHA** rules and regulations relating to this type of product. Units should be tested regularly.